

CARNOT User Meeting, Innsbruck, 2022-07-01

Development of control concepts for heat exchangers for highly flexible usage in the test facility “District LAB” with the CARNOT blockset

Dennis Lottis

Supported by:



Federal Ministry
for Economic Affairs
and Climate Action



on the basis of a decision
by the German Bundestag



Low temperature district heating is one of the most efficient technology solutions to achieve 100% renewable and GHG emission-free energy systems on a community level. «

Final Report of IEA DHC Annex TS1,
FUTURE LOW TEMPERATURE DISTRICT HEATING DESIGN GUIDEBOOK

Scope of the Investigation



- Joint project "UrbanTurn" funded by the Federal Ministry for Economic Affairs and Climate Action: suitable transformation measures for existing district heating (DH) networks
- For this: Experimental facility for DH applications "District LAB" by Fraunhofer IEE in Kassel
- In this work: Focus on the flexible heating grid (FHG)

- Hardware-in-the-loop (HIL) units should map producer, consumer or prosumer in the FHG
- Heat removal or supply via secondary circuits: Hot Circuit (HC), Cold Circuit (CC)
- Interaction with the FHG via heat exchanger
- **Necessary: Control of heat flow and secondary side outlet temperature simultaneously**

Related Approaches


Special Control Task for Heat Exchangers (HEX)

- Typically only one outlet temperatures is controlled
- Commercial DH house transfer stations: Secondary side outlet temperature is controlled by a primary side valve
- Scientific literature: No solution for a comparable control task found; only for temperature controls

Development of own two variable control


- Cascaded Control?
 - Similar time behaviour of the two control circuits because of their dependency on the heat capacity of the HEX => Does not work
- Idea: Decoupling with a Feed Forward Control based on:

$$\dot{Q} = \dot{m}_{sec} \cdot c_{p,sec} \cdot \Delta T_{sec}$$




© Danfoss, Handbuch über Fernwärmanwendungen

Developed Control Concepts



Control Concept: “Decoupled PID Controller”

- Secondary side mass flow $u_1(t)$ is manipulated by Feed Forward Control (decoupling)
- Primary side mass flow $u_2(t)$ is manipulated by PID-Controller
- Secondary side outlet temperature $y_2(t)$ is the controlled variable





Control Concept: “Characteristic Field Based Control”

- PID controller is replaced by a lookup table with a characteristic Field (CF)
- Weak parameterised I controller for the final correction
- Other allocation of the vectors $w(t)$ and $u(t)$ necessary

Determination of the Characteristic Field






© Dennis Lotis, Fraunhofer IEE



Reduction of the number of dimensions: $\dot{m}_{pri} = f(\dot{Q}, \Delta T_{in}, \Delta T_{sec})$

Variable	Min.	Max.	Step Size	Step Number
\dot{Q}	100 W	60000 W	1000 W	60
ΔT_{in}	5 °C	90 °C	5 °C	18
ΔT_{sec}	5 °C	40 °C	5 °C	8

8640 Simulation runs



— Feed Forward Control — Different Control Structure

Simulation Model for Comparison

Investigation Scenarios

48 different Scenarios for Simulation:

- Step response type:
 - Heat Flow step
 - Temperature step
 - Both steps together
- Temperature Level:
 - Conventional grid: 130 °C
 - Low-temperature grid: 80 °C
- Heat Flow Level:
 - low: ~ 10 kW
 - high: ~ 50 kW
- Time constant of PT1 elements:
 - 1 s
 - 2 s
- Factor for heat exchanger model parameters:
 - 1
 - 1.5

Scenario Name	Step Type	Temperature Level	Power Level	Parameter Factor	Time Constant PT1
1-Q	Power	80	Low	1	1
1-T	Temperature	80	Low	1	1
1-TQ	Temperature & Power	80	Low	1	1
2-Q	Power	130	Low	1	1
2-T	Temperature	130	Low	1	1
2-TQ	Temperature & Power	130	Low	1	1
3-Q	Power	80	Low	1	2
3-T	Temperature	80	Low	1	2
3-TQ	Temperature & Power	80	Low	1	2
4-Q	Power	130	Low	1	2
4-T	Temperature	130	Low	1	2
4-TQ	Temperature & Power	130	Low	1	2
5-Q	Power	80	Low	1,5	1
5-T	Temperature	80	Low	1,5	1
5-TQ	Temperature & Power	80	Low	1,5	1
6-Q	Power	130	Low	1,5	1
6-T	Temperature	130	Low	1,5	1
6-TQ	Temperature & Power	130	Low	1,5	1
●	●	●	●	●	●
●	●	●	●	●	●
●	●	●	●	●	●
13-Q	Power	80	High	1,5	1
13-T	Temperature	80	High	1,5	1
13-TQ	Temperature & Power	80	High	1,5	1
14-Q	Power	130	High	1,5	1
14-T	Temperature	130	High	1,5	1
14-TQ	Temperature & Power	130	High	1,5	1
15-Q	Power	80	High	1,5	2
15-T	Temperature	80	High	1,5	2
15-TQ	Temperature & Power	80	High	1,5	2
16-Q	Power	130	High	1,5	2
16-T	Temperature	130	High	1,5	2
16-TQ	Temperature & Power	130	High	1,5	2

Results

Comparison Factor

Based on Root Mean Square Error (RMSE):


$$RMSE_{j,k}(x) = \sqrt{\frac{\sum_{i=1}^n (x_{actual,j,k,i} - x_{target,k,i})^2}{n}}$$

$$j \in \{CF, PID\}, k \in \{1 - Q, \dots, 16 - TQ\}, x \in \{\dot{Q}, T_{sec,out}\}$$

$$f_{c,k} = \frac{\overline{RMSE}_k(x) + RMSE_{CF,k}(x)}{\overline{RMSE}_k(x) + RMSE_{PID,k}(x)}$$

$\Rightarrow f_{c,k} < 1 \Rightarrow$ CF performs better and vice versa

No concepts outperforms the other, but very different performance based on scenario!



Results


Step Response Error Plots

CF-based control:

- Slow reaction to the step
- Few overshoots or oscillatory behavior
- Moderate influence of scenarios (mean values vs percentiles)

PID-based control:

- Fast reaction to the step
- A lot of overshoots and oscillatory behavior
- Large influence of scenarios (mean values vs. percentiles)



Conclusion and Outlook

CF-based control concept seems better suited for the District LAB

- No concept outperforms based on the compare factor
- Planned at District LAB: Solar thermal or room heating profiles
- Very slow changes compared to the steps in this investigation
- Lesser overshoots but slower reaction time is favourable

Further investigation planned when more precise knowledge of the components is available

Shown methods might be useful for other test facilities

Contact

Dipl. -Ing. Dennis Lottis
Department: Thermal Energy System Technology
Phone: +49 561 7294-1547
dennis.lottis@iee.fraunhofer.de

Fraunhofer IEE
Joseph-Beuys Straße 8
34117 Kassel | Germany
www.iee.fraunhofer.de

Thank you for your attention!

